

TEST CERTIFICATE

for tests according to DVGW standard W 270 (11/2007)

Manufacturer: Frenzelit-Werke GmbH, Bad Berneck
Test item: test plates, flat gasket-quality
Name of material: novapress® 260
Date of reception: 30.11.2016
Samples taken by: manufacturer
TZW-reference no.: MO 249/16

The presented material novapress® 260 complies with regard to microbiological aspects with the requirements of DVGW standard W 270 (11/2007).


The detailed test results are given in a separate test report.

The validity is fixed by other instructions and expires on 31.12.2021 at the latest.

The test certificate becomes invalid if the material composition or manufacturing process has been changed.

The test certificate is based on the first test (TZW ref.-no. MO 249/16).

Karlsruhe, 29.05.2017


Dr. J. Klingner / i.V. Dr.-Ing. R. Turković
Head of the Test Centre

The publication of this test certificate - completely or in parts - is not permitted except of written approval by the test centre